

Lombard House
145 Great Charles Street
Birmingham, B3 3LP



Date 19/07/2023 12:13
File

Designed by Link Engineering
Checked by

Innovyze

Source Control 2020.1.3

ICP SUDS Mean Annual Flood

Input

Return Period (years) 100 SAAR (mm) 700 Urban 0.000
Area (ha) 3.859 Soil 0.300 Region Number Region 4

Results 1/s

QBAR Rural 7.0
QBAR Urban 7.0

Q100 years 18.1

Q1 year 5.8
Q30 years 13.8
Q100 years 18.1